

Liquor License Building Division Review

Name of Business: Hitching Post
Address: 2341 N Apache Trail
Liquor License Applicant: Mohiuddin Mehmood
License requested: TEMPORARY EXTENSION OF PREMISES
Date of Review: September 6, 2017

Event- Darryl Singletary Concert- November 5, 2017

Findings- Mr. Mehmood proposes to use an area adjacent to the Hitching Post, southwest of the Hitching Post Restaurant to host an outdoor concert with alcohol to be served. A significant amount of the perimeter is enclosed by a previously constructed wall/ fake western façade. This non roofed area has sufficient egress for up to 500 persons as long as no locking gates or other obstructions are placed at the exits shown on the diagrams submitted.

Building Division Recommendation- The Building Division finds no Building Code reasons for denial of the temporary one day extension of premises as long as 6 temporary water closet facilities, with minimum of 1 Accessible water closet are provided.

***Additional Notes-** *The diagrams submitted by Mr. Mehmood contain references to elements that are not approved. The approval of the extension of premises in no way includes a volleyball area, gazebo, water fall or any other improvements to any of the properties.*