



Legislation Text

File #: 19-078, **Version:** 1

Presentation, discussion and consideration of approval to construct and install a new 800 amp service entrance section and 600kW generator at Booster Station 2 / Well 6, located at 575 E. Baseline Avenue. This is to replace an existing electrical service entrance section that no longer meets SRP's specifications and install a new generator. The construction would be through the City of El Mirage Job Order Contract Water and Wastewater Projects - PW19 - JOC02 with an amount not to exceed \$179,523.80.